

Approval Number: 1607508  
Test Report: MAT/LAB 6262K/a, MAT/LAB 147L & MAT/LAB 148L



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

31<sup>st</sup> October 2016

Aquakote Systems Ltd.  
Riverside House,  
River Lawn Road,  
Tonbridge,  
Kent  
TN9 1EP

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**COATINGS, PAINTS & LININGS - SITE APPLIED CISTERN COATINGS.**

**5046**

Aquakote (Blue). Blue coloured, two part epoxy resin coating, consisting of PART A base (blue liquid) and PART B hardener (amber liquid). Mix as per manufacturer's instructions (REF: MS0006.03.16), before applying a single coat to achieve a wet film thickness of 200µm. Cure for 12 hours at 10°C. Aquakote (Grey). Grey coloured, two part epoxy resin coating, consisting of PART A base (grey liquid) and PART B hardener (amber liquid). Mix as per manufacturer's instructions (REF: MS0006.03.16), before applying a single coat to achieve a wet film thickness of 200µm. Cure for 12 hours at 10°C. Aquakote (Grey/Blue) (2 Coat system). Blue coloured (final appearance), two part epoxy resin coating, applied in two coats. Coat 1 (Grey) consists of PART A base (grey liquid) and PART B hardener (amber liquid). Mix as per manufacturer's instructions (REF: MS0006.03.16), before applying a single coat to achieve a wet film thickness of 200µm. Cure for 12 hours at 10°C, before applying Coat 2. Coat 2 (Blue) consists of PART A base (blue liquid) and PART B hardener (amber liquid). Mix as per manufacturer's instructions (REF: MS0006.03.16), before applying a single coat to achieve a wet film thickness of 200µm. Cure for 12 hours at 10°C. All are for use with water up to 23°C. These materials are only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the materials are not covered by the scope of the approval.

**APPROVAL NUMBER: 1607508**

**APPROVAL HOLDER: AQUAKOTE SYSTEMS LTD.**

The Scheme reserves the right to review approval.  
Approval 1607508 is valid between July 2016 and July 2021

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme

## **WRAS MATERIAL APPROVAL - MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY**

The material referred to in this letter is suitable for contact with water for domestic purposes. **Approval of this material does not signify the approval of its mechanical or physical properties for any use.**

Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that; 'the material as listed, having passed the tests of effect on water quality, is suitable for use in contact with wholesome water'

This may be abbreviated to 'Water Regulations Advisory Scheme - Approved Material' or 'WRAS Approved Material'.

The scope of an Approval does not extend to rebranded materials unless otherwise agreed by the Scheme.

### **Use of the WRAS Approved Material Logo**

Approval holders may use the WRAS Approved Material logo and make reference to any approval issued by WRAS Ltd. in respect of a particular material or range of materials provided the approval is, and remains valid.

Approval holders are entitled to use the logo on the packing, promotional literature and point of sale advertising Approved Materials.

### **Modifications to existing Approvals**

It is a condition of WRAS Material Approval that NO changes or modifications to the Approved Material, be made without the Approval Holder first notifying WRAS Ltd. Full details of the proposed changes must be provided to the Scheme. Failure to comply with this condition will immediately invalidate a previously granted Approval.

### **Re-Approval**

WRAS will write to you 1 year before the approval expires asking whether you would like to renew it. Please complete the relevant section of the MA3 application form which will be included with the letter and return to WRAS (via e-mail or post).

Please note it is the responsibility of the Approval Holder to ensure the Approval remains valid. WRAS Ltd. accepts no liability for the delay in granting approval where this is caused by circumstances outside of the Scheme's control.